

DATA SHEET

battery fuse protection

enwitec-Article-No.	10015451
Customer-Article-No.	
Matchcode	Bat Breaker-BYD_LVLPR_3xAcc_3xCharg_KS_exsf
Application	Battery fuse "BAT BREAKER" for the PV energy storage system with battery charger / inverter
Number and type of battery charger / inverter:	Max. 3 Sunny Island
Number and type of energy storage:	Max 3x BYD B-Box Premium LVL
General note:	If a different battery charger / inverter is to be used, the suitability of the circuit breaker used (nominal value, tripping characteristic) must be checked by BYD Cable lugs are not included


Min. Distances:

Up and down min. :
300 mm

Left and right min. :
200 mm

After Front min.:
800 mm

Cable clamping:
Must be done on site!



Delivery			
Designation	Article-No.	piece	comments
Pflitsch cable gland M32x1,5	10011807	12	
Locknut M32x1,5	10000724	12	
Twisting Sleeve M32 x 1.5	10008835	2	

