

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Surge protective device

Name and address of the applicant

Kostal Solar Electric GmbH
6 Hanferstrasse, 79108 Freiburg Im Breisgau, Germany

Name and address of the manufacturer

KOSTAL Industrie Elektrik GmbH & Co. KG
Lange Eck 11, 58099 Hagen, Germany

Name and address of the factory

KOSTAL Industrie Elektrik GmbH & Co. KG
Lange Eck 11, 58099 Hagen, Germany*When more than one factory* Additional information on page 2

Ratings and principal characteristics

Product data

Rating: Test Class II, Ucpv 1000 V, In 5 kA, Up ≤ 2,8 kV, Iscpv 40 A

Trademark / Brand (if any)

KOSTAL

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

OVPD DC TYPE 2 G3

Additional information

 Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-31:2018

National differences:
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

2280026.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 8 March 2024


Signature: H.L. Schendstok