



Product Service

# Attestation of Conformity

No. N8A 072092 0292 Rev. 00

**Holder of Certificate:** Shanghai JA Solar Technology Co., Ltd.

No. 118, Lane 3111,  
West Huancheng Road  
Fengxian District  
201401 Shanghai  
PEOPLE'S REPUBLIC OF CHINA

**Product:** Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 704061604115-14

**Date,** 2018-12-04 ( Zhulin Zhang )

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®





Product Service

# Attestation of Conformity

No. N8A 072092 0292 Rev. 00

## Model(s):

1500 V DC Maximum System voltage,  
 Fire Safety Class C Modules:  
 JAM6(K)-72-xxx/PR/1500V, xxx= 345 to 370 in step of 5;  
 JAM6(K)-60-xxx/PR/1500V, xxx= 285 to 310 in step of 5;  
 JAM6(K)-72-xxx/4BB/1500V, xxx= 320 to 345 in step of 5;  
 JAM6(K)-60-xxx/4BB/1500V, xxx= 265 to 285 in step of 5;  
 1500 V DC Maximum System voltage,  
 Fire Safety Class A Modules:  
 JAM72D00-xxx/BP, xxx= 330 to 370 in step of 5;  
 JAM60D00-xxx/BP, xxx= 275 to 310 in step of 5;  
 JAM60D00-xxx/PR, xxx= 285 to 315 in step of 5;  
 JAM72D00-xxx/PR, xxx= 340 to 370 in step of 5;  
 JAM60D00-xxx/MB, xxx= 310 to 315 in step of 5;  
 JAM72D00-xxx/MB, xxx= 370 to 380 in step of 5;  
 1000 V DC Maximum System voltage,  
 Fire Safety Class C Modules:  
 JAM6(K)-72-xxx/PR, xxx= 345 to 370 in step of 5;  
 JAM6(K)-60-xxx/PR, xxx= 285 to 310 in step of 5;  
 JAM6(K)-72-xxx/4BB, xxx= 320 to 345 in step of 5;  
 JAM6(K)-60-xxx/4BB, xxx= 265 to 285 in step of 5;  
 JAM72S02-xxx/PR, xxx= 345 to 375 in step of 5;  
 JAM60S02-xxx/PR, xxx= 285 to 310 in step of 5;  
 JAM72S02-xxx/SC, xxx= 320 to 365 in step of 5;  
 JAM60S02-xxx/SC, xxx= 265 to 305 in step of 5;  
 JAM72S02-xxx/MR, xxx= 365 to 385 in step of 5;  
 JAM60S02-xxx/MR, xxx= 305 to 320 in step of 5;  
 JAM72S08-xxx/PR, xxx= 360 to 385 in step of 5;  
 JAM60S08-xxx/PR, xxx= 300 to 320 in step of 5;  
 1000 V DC or 1500 V DC Maximum System voltage,  
 Fire Safety Class C Modules:  
 JAM72S01-xxx/SC, xxx= 320 to 365 in step of 5;  
 JAM60S01-xxx/SC, xxx= 265 to 305 in step of 5;  
 JAM72S01-xxx/PR, xxx= 345 to 380 in step of 5;  
 JAM60S01-xxx/PR, xxx= 285 to 315 in step of 5;  
 JAM72S01-xxx/MR, xxx= 365 to 385 in step of 5;  
 JAM60S01-xxx/MR, xxx= 305 to 320 in step of 5;  
 JAM72S03-xxx/PR, xxx= 360 to 385 in step of 5;  
 JAM60S03-xxx/PR, xxx= 300 to 320 in step of 5;  
 xxx is standing for rated output power at STC

## Parameters:

Construction:	Framed or Frameless, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute; No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC or 1000 V DC

## Tested according to:

EN 61730-1:2018  
 EN 61730-2:2018

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.